

ATEX Examination Certificate

Epsilon Certificate Number:

Epsilon 02ATEX1168

This certificate is issued for the electrical equipment:

CYCLOPS Zone 2 Purge Indicator

Manufactured and submitted by:

Purge Solutions, Inc.
PO Box 2223, Friendswood, Texas, 77549, USA

The equipment shall be designed and constructed in accordance with the specification set out in the schedule herein and documents referred to therein.

This Certificate is issued subject to the conditions of Epsilon Compliance and any additional conditions as may be prescribed.

This Certificate does not imply that the equipment meets all statutory requirements in any particular industry or circumstance.

Directive/s:

ATEX Directive, 94/9/EC

Standard/s

EN50021: 1999

Coding:

CE  II 3 GD EEx nL [nP] IIC T6

Project Number:

ETS0643

Issue Date:

02 December 2002

Report Number:

RETS(A)0643/A/1



On Behalf of Epsilon Compliance

S L D'Henin
Certification Manager

This certificate may only be used in its entirety and without change



1 of 2



ATEX Examination Certificate Schedule

Epsilon Certificate Number:

Epsilon 02ATEX1168

Equipment Description:

The Type CYCLOPS Zone 2 Purge Indicator provides indication of positive enclosure pressure. A visible indicator and dry-contact output for remote status monitoring provide the pressure status indication. The enclosure purge outlet vent is an integrated part of the unit. The main electronics of the unit and the pressure switch are fully encapsulated. The electrical connection facilities are provided by the use of screw type terminals mounted on the rear of the unit.

Drawings:

Number	Rev	Date	Title
MM-10002-D	D	13/SEPT/02	Housing, Labelling, Cyclops, Purge Indicator.
MM-10001-B	B	06/AUG/02	Housing, Cyclops, Purge Indicator.
EB-11013-A	A	01/DEC/02	PC Board, Fabrication Printout, Cyclops, Purge Indicator.
EB-11014-A	A	01/DEC/02	PC Board, Assy., Cyclops, Purge Indicator.
EB-11015-A	A	01/DEC/02	115/230 Volt, Schematic, Cyclops, Purge Indicator.

Conditions of Certification:

None

Special Conditions of Certification:

None



This certificate may only be used in its entirety and without change



2 of 2