



12450 Galveston Road, Suite C, Webster, Texas 77598, USA
Phone: 832-368-7166 Fax: 281-992-5726
info@purgesolutions.com
http://www.purgesolutions.com

CE Declaration of Conformity

Equipment Model: CYCLOPS Z – Purge Indicator

Model Numbers: PSCZ-1A, PSCZ-1S, PSCZ-2A, PSCZ-2S, PSCZ-3A, PSCZ-3S, PSCZ-4A, PSCZ-4S, PSCZ-1AD, PSCZ-1SD, PSCZ-2AD, PSCZ-2SD, PSCZ-3AD, PSCZ-3SD, PSCZ-4AD and PSCZ-4SD

Manufacturer: Purge Solutions, 12450 Galveston Road, Suite C, Webster, Texas 77598, USA

Product Complies In Accordance With

European Directive: 94/9/EC, ATEX Directive
ATEX standards compliance with as follows: EN 60079-0:2006, EN 60079-2:2007, EN 60079-15:2004, EN 61241-0:2006 and EN 61241-12004.
ATEX markings as follows: Ex II 3 G Ex nA nL [pz] IIC T6 -40°C ≤ Tamb ≤ +65°C
Ex II 3 D Ex tD A22 IP66 79°C
EC-Type examination certificate number: DNV 09 ATEX 52751X

European Directives: 2004/108/EC, Electromagnetic Compatibility Directive, “EMC” and 2006/95/EC, Low Voltage Directive, “LVD”
EMC and LVD standards compliance with as follows: IEC 61000-4-2:2008, IEC 61000-4-3:2008, IEC 61000-4-4:2004, EN 61000-4-5:2006, EN 61000-4-6:2007, EN 61000-4-8:1994, EN 61000-4-11:2004, BS EN 61000-6-2:2005, BS EN 61000-6-4:2007, EN 55011:Cispr 11:2007, EN 60204:2006 and EN 61326:2006.

Signature of Manufacturer:

Signature

DeWayne Skipper
Name

July 11, 2011
Date

Quality Manager
Title