



12450 Galveston Road, Suite C, Webster, Texas 77598, USA
 Phone: 832-368-7166 Fax: 281-992-5726
 info@purgesolutions.com
 http://www.purgesolutions.com

CE Declaration of Conformity

Equipment Model: TRYCLOPS X – Purge Controller, SM Version

Model Numbers: PSTS-11, PSTS-12, PSTS-21, PSTS-22, PSTS-31 and PSTS-32

Manufacturer: Purge Solutions, 12450 Galveston Road, Suite C, Webster, Texas 77598, USA

Product Complies In Accordance With

European Directive: 94/9/EC, ATEX Directive

ATEX standards compliance with as follows: EN 60079-0:2006, EN 60079-2:2007, EN 60079-7:2007, EN 60079-11:2007, EN 60079-18:2004, EN 61241-0:2006 and EN 61241-12:2004.

ATEX markings as follows: Ex II 2 G Ex e mb ib [px] IIC T4 -40°C ≤ Tamb ≤ +65°C

Ex II 2 D Ex tD A21 IP66 119°C

EC-Type examination certificate number: DNV 09 ATEX 48607X

European Directives: 2004/108/EC, Electromagnetic Compatibility Directive, “EMC” and 2006/95/EC, Low Voltage Directive, “LVD”

EMC and LVD standards compliance with as follows: IEC 61000-4-2:2008, IEC 61000-4-3:2008, IEC 61000-4-4:2004, EN 61000-4-5:2006, EN 61000-4-6:2007, EN 61000-4-8:1994, EN 61000-4-11:2004, BS EN 61000-6-2:2005, BS EN 61000-6-4:2007, EN 55011:Cispr 11:2007, EN 60204:2006 and EN 61326:2006.

Signature of Manufacturer:

Signature

December 1, 2009

Date

DeWayne Skipper
Name

Quality Manager
Title